

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 8-31-10 Time 8:00 p.m. Location 112 Foster Ave

Case / Issue Appropriate Action: New Line Installation Line Repair Service Line

COPY

NEW LINE INSTALLATION

Were State approved or AWWA Standards Followed (YES NO)
Detailed summary of disinfection procedure used (Use back of page if needed)

Chlorine Residual Prior to Initial Flush
Date Time of Initial Flush Length of Time of Initial Flush
Chlorine Residual after Flush

Water Supply WS Project Number

FOR LINE REPAIRS

Interruption of Water Service YES NO Number of Customers Affected

Main Size Repaired Under Pressure YES NO

For partially or fully de-watered mains

Was positive pressure maintained while a trench was opened and area cleaned? (YES NO)

Time Water Main Valved Off (positive pressure removed) am/pm

Nature of Leak or Break
Replace service

Were State approved or AWWA Standards Followed (YES NO)
Detailed summary of repair procedure used (Use back of page if needed)

Replace 3/4 Blue Max with copper

Was water main contaminated during the repair process? (YES NO)

Disinfection Procedure Calculations (Use back of page if needed)
Flushed line

Amount of Time Line Flushed Minutes Ending Chlorine Residual mg/L 2.20

Bacteriological Sample Collected YES NO Results\*\*
\*\* Attach copy of results to record

Date Time Water Main Returned to Service am/pm

Additional Comments

Handwritten signature

100/100