

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 10-17-11 Time: 1:30 Location: 2419 Swan Pond Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

COPY

Were State approved or AWWA Standards Followed: (YES / NO)  
Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_  
Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial  
Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

FOR LINE REPAIRS:

Interruption of Water Service: YES \_\_\_ NO  Number of Customers Affected: \_\_\_\_\_

Main Size: 8 Repaired Under Pressure: YES  NO \_\_\_\_\_

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break: pinhole in service line

Were State approved or AWWA Standards Followed: (YES / NO) NO Repaired with Band  
Detailed summary of repair procedure used (Use back of page if needed):

Was water main contaminated during the repair process? (YES / NO) NO Bleached Band  
Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: \_\_\_\_\_ Minutes Ending Chlorine  
Residual: \_\_\_\_\_ mg/L

Bacteriological Sample Collected: YES \_\_\_ NO \_\_\_ Results\*\*: \_\_\_\_\_  
(\*Attach copy of results to record)

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments:

Aden - Kim - Bull

COPY